ATTAR TEST REPORT NUMBER: 14/8054.3



The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Accredited for compliance with ISO/IEC 17025.

Accreditation Number: 2735

14 July 2014

Total Pages: 2

Job No: M14/8054

WET PENDULUM SLIP RESISTANCE

Prepared for:	Gerflor Australasia Pty Ltd					
	17 Cato Street					
	HAWTHORN EAST VIC 3123					
Attention:	Jutta Fronert					
Test Site:	ATTAR, Unit 1, 64 Bridge Road, Keysborough.					
Test Date:	10 July 2014					
Test Specimens, Size &	Creation Clic vinyl plank, 1000x176 mm, 5 off tested.					
Quantity:	Refer to Figure 1.					
Sampling & Direction of Testing:	Sampling conducted by client. Test direction parallel					
	with grain profile.					
Test Personnel:	Sean Lake					
Preparation:	Washed with water and pH Neutral detergent, rinsed					
	then dried.					
Fixed/Unfixed:	Unfixed.					
Air Temperature:	21°C					
Test Equipment:	Munro Stanley Skid Resistance Tester (Pendulum)					
	Serial Number 0320, Calibrated 16/10/2013.					
Test Standard:	AS 4586: 2013 Slip resistance classification of new					
	pedestrian surface materials – Appendix A.					
Slider Rubber:	Slider 96 Batch No. #54 prepared on P400 & 3µm					
	lapping film.					
Classification Criteria:	Refer to Classification Criteria, attached as Appendix 1.					
	Specimen Number					CDV
British Pendulum Number	1	2	3	4	5	SRV
	27	27	28	27	26	27
Classification:	P2					

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance procedures and wear on their slip-resistance be checked.

NOTE: Any specimens supplied will be disposed of in two (2) months time, unless otherwise instructed.

ATTAR

Daniel King BEng (Mats) Hons, Materials and Testing Engineer

Approved Signatory

This report may not be reproduced except in its entirety.